

EFFLUENT/WASTE WATER
INCLUDING AGRICULTURAL, IPW, MUNICIPAL, TREATMENT WORK, DESALINATION PLANTS

MICROBIOLOGICAL PARAMETERS			
PARAMETER	UNIT	RISK	LIMIT
Faecal coliforms	Count per 100ml	Acute	None found
E.coli	Count per 100ml	Acute	None found